



NOTES:

1. CONCRETE BLOCKING IS TO BE FORMED TO ENSURE ACCESSIBILITY TO FITTINGS AND POURED AGAINST UNDISTURBED EARTH.
2. FITTINGS ARE TO BE COMPLETELY WRAPPED WITH PLASTIC, PRIOR TO POURING CONCRETE.
3. CONCRETE TO BE MINIMUM 3,000 PSI. @ 28 DAYS.
4. RESTRAINT LENGTH MUST BE COMPUTED. WHEN COMPUTING LENGTH OF BRANCH TO BE RESTRAINED, DESIGNER TO ASSUME LENGTH OF RUN ON LINE BEING TAPPED = "0". LENGTH OF BRANCH REQUIRED FOR RESTRAINT TO BE SHOWN ON PLANS.



TITLE: STANDARD TAPPING SLEEVE AND VALVE ASSEMBLY (4"-24") PO BOX 1436 900 S. BECKFORD DRIVE HENDERSON, NC 27536	REV DATE: 7/31/15	DWG NO: W.010
	SCALE: NTS	SHEET #: 1 OF 1

CITY OF HENDERSON

252-430-5728
 (fax) 252-431-0124
 www.ci.henderson.nc.us